

38MM PLASTERBOARD RYANFIRE MASTIC RYANSPAN



- 1. ENSURE THE APERTURE IS CLEAN AND FREE OF DUST AND DEBRIS.
- 2. THE APERTURE MUST BE FULLY FRAMED AND LINED.
- 3. APPLY A BEAD OF RYANFIRE MASTIC TO THE INTERNAL FACES OF THE APERTURE.
- 4. SELECT THE CORRECT WIDTH OF RYANSPAN REQUIRED FOR THE GAP.
- 5. COMPRESS THE RYANSPAN AND FIT IT WITHIN THE GAP TO SIT CENTRALLY WITHIN THE GAP.
- 6. TO JOIN TWO PIECES OF RYANSPAN, APPLY RYANFIRE HP-X TO EACH END AND BUTT THEM UP AGAINST EACH OTHER. ENSURE A TIGHT FITTING SEAL.
- 7. WHEN 50MM RYANSPAN IS REQUIRED, 2 LAYERS ARE REQUIRED. JOINTS MUST BE STAGGERED BY A MINIMUM OF 200MM



Web based drawings are for example only. Fire performance of any system is dependant on, but not limited to size of opening, substrate, if penetrations are

RYANSPAN

23SFR00071 A - C

Linear gap seal

Up to 100mm wide

Note that using the 50mm Ryanspan requires 2 layers.

237

ceiling

Fire Insulation: 120 minutes

120 minutes

RYANFIRE MASTIC RYANFIRE HP-X

AS 1530.4/AS 4072.1

Min 38mm thick FR plasterboard

Products:

Approvals:

Scenario:

Void Size:

Construction:

Fire Integrity:

BK:

Ref:

Ryanfire technical department for detailed and specific fire performance information.



passing through, type, size and number. Please refer to

RYANFIRE Technical Support: info@ryanfire.co.nz - Tel 09 443 0362

Drawing Title

Ryanspan linear gap seal 38mm plasterboard ceiling

NTS Date
December 2023

Drawing Number Rev

All errors and omissions excepted. The information contained within this drawing is believed to be correct on the date of publication, and is based upon tested and certified solutions. The policy of Ryanfire Products Ltd is one of constant improvement. Installers must ensure that they are following the latest published drawings, test evidence and instructions. Whilst Ryanfire Products Ltd will endeavour to keep its publications up to date, the accuracy of the information contained within this drawing may be affected by pertinent changes in the law or regulatory requirements and alterations or amendments to the specification of the manufactured products. Terms and conditions of sale apply.

Ryanfire Products Ltd owns and has copyright to these drawings. They are to be used only for the purpose for which they were intended and supplied and are not to be sold, transferred or made available for use by a third party. Any misuse of these drawings will result in legal proceedings.

V67.11

1.0