

# VOC Content Test Certificate

Thursday 08<sup>th</sup> August 2024

Supplier: Trafalgar Group Pty Ltd (26 Ferndell Street, South Granville, NSW 2128, Australia).

Product name: Trafalgar FyreFLEX Fire Resistant Sealant

Date Tested: August 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Buildings V1 Revision C</b> <b>Exposure to Toxins Credit 13</b>	<b>Trafalgar FyreFLEX</b> <b>Fire Resistant Sealant</b>
<b>Fire Retardant Sealants and Adhesives Limit:</b> <b>250 grams per litre</b>	<b>74 grams per litre as VOC content per material</b>
<i>We hereby certify FyreFLEX sealant is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant