

# VOC Content Test Certificate

Thursday, 17<sup>th</sup> April 2014

Manufacturer: Trafalgar Fire Containment (26 Ferndell Street, South Granville, NSW 2128)

Sample Description: Trafalgar Fyreflex

Date Tested: April 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Trafalgar Fyreflex</b>
Architectural Sealants  250 grams per Litre as VOC content per material	<b>71 grams per Litre as VOC content per material</b>

\*Sealants used to enhance the fire and water-proofing properties are included



Dr. Vyt Garnys  
PhD, BSc(Hons) AImm, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV140410**