

VOC Content Test Certificate

Monday, 02nd July 2018

Supplier: Trafalgar Fire Containment Solutions (26A Ferndell Street, South Granville, NSW

2142 Australia).

Sample Description: Fyrepex HP Sealant

Date Tested: 2nd July 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various

Materials as referenced by South Coast Air Quality Management District (SCAQMD)

Rule 1168.

Test Data:

Specification

Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B

Fyrepex HP Sealant

Fire retardant sealants and adhesives: 250 grams per Litre as VOC content per material

7 grams per Litre as VOC content per material

We hereby certify Fyrepex HP Sealant is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia

Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant

Tuan Duong BE (Chem. Eng.) Consultant Nick Joy BSc (Hons) Consultant

CV180605A